



TITLE CU2.2000.AB	
DRAWN BY J. Ellison	DATE 19/01/2022
CUSTOMER CUSTOMER	

NOTE:
All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

DESCRIPTION:
CU2.2000.AB Combination Unit c/w AB Air gap

A4

ALL DIMENSIONS IN MM - DO NOT SCALE

DATE	VERSION	NOTES
22/12/2021	A	FIRST ISSUE

TANK SPECIFICATION :	
WET COMPARTMENT	1000 x 1800 x 1800mm
DRY COMPARTMENT	1500 x 1800 x 1800mm
EXTERNAL DIMENSIONS	2660 x 1960 x 1918mm
NOMINAL CAPACITY	3240 Litres
DRY WEIGHT	XXX KG
INSULATION THICKNESS	25mm
MATERIAL	GRP



SCALE:1:35 SHEET 1 OF 1