



**Connections:**

- A - Inlet
- B - Lid vent
- D - Overflow 1 No pad T6 only
- F1 - Outlet 1 No pad T6 only
- G - Drain 1 No pad T6 only
- H - Spillover 1 No SPO1 fitted

Drawing Approval Date	
Name	
Signature	

I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.

RUBBED DOWN BY		PRINT NAME
TITLE		STANDARD POSITIONS
DRAWN BY	DATE	
D.PRYJMACHUK	03/04/2024	
CUSTOMER		CUSTOMER

NOTE:  
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:  
**PW305.INS.AB**

NOTES	
DATE	08/03/2024
FIRST ISSUE	xxx
VERSION	xxx

**TANK SPECIFICATION :**

INTERNAL DIMENSIONS	500 X 500 X 1220mm
EXTERNAL DIMENSIONS	690 X 690 X 1530mm
NOMINAL CAPACITY	305 Litres
INSULATION THICKNESS	25mm
STEEL BRACINGS	25mm STEEL BRACES
ENCAPSULATED BASEBOARD	NONE
TANK COLOUR	GREY - 00A05

