



Connections:

- A - Inlet 1 No pad T6
- B - Lid vent None
- D - Overflow 1 No pad T2
- F1 - Outlet 1 No pad T6
- G - Drain 1 No pad T6

Drawing Approval	
Date	
Name	
Signature	
<p style="color: red; font-size: small;">I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.</p>	

RUBBED DOWN BY		PRINT NAME
<p><b>TITLE</b> STANDARD POSITIONS</p>		
DRAWN BY	DATE	
C.LARKIN	28/03/2024	
<p><b>CUSTOMER</b> CUSTOMER</p>		

**NOTE:**  
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

**DESCRIPTION:**  
PW650.INS

ALL DIMENSIONS IN MM - DO NOT SCALE

NOTES		TANK SPECIFICATION :	
DATE	08/02/2023	INTERNAL DIMENSIONS	1067 x 610 x 1000mm
FIRST ISSUE	xxx	EXTERNAL DIMENSIONS	1245 x 805 x 1039mm
VERSION	xxx	NOMINAL CAPACITY	650 Litres
		INSULATION THICKNESS	25mm
		STEEL BRACINGS	2 No 25MM BANDS
		ENCAPSULATED BASEBOARD	
		TANK COLOUR	GREY - 00A05



SCALE: 1:20

SHEET 1 OF 1