



Connections:

- A - Inlet
- B - Lid vent
- D - Overflow 1No pad T6
- F1 - Outlet 1No pad T1
- G - Drain 1No pad T1
- H - Spillover 1No SPO3 fitted to FVH

Drawing Approval Date	
Name	
Signature	

I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.

RUBBED DOWN BY		PRINT NAME
TITLE <b>STANDARD POSITIONS</b>		
DRAWN BY D.PRYJMACHUK	DATE 22/04/2024	
CUSTOMER CUSTOMER		

**NOTE:**  
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:  
**PW680-AB4**

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

NOTES	DATE	TANK SPECIFICATION :	
	10/03/2023	INTERNAL DIMENSIONS	1220 x 915 x 610mm
FIRST ISSUE	xxx	EXTERNAL DIMENSIONS	1395 x 1087 x 950mm
VERSION	xxx	NOMINAL CAPACITY	680 Litres
		INSULATION THICKNESS	25mm
		STEEL BRACINGS	NONE
		ENCAPSULATED BASEBOARD	NONE
		TANK COLOUR	GREY - 00A05



SCALE:1:20

SHEET 1 OF 1