



**Connections:**

- A - Inlet 1 No pad T1 only
- B - Lid vent None
- D - Overflow 1 No pad T2 only
- F1 - Outlet 1 No pad T1 only
- G - Drain 1 No pad T1 only

Drawing Approval Date	
Name	
Signature	
<p style="font-size: small; color: red;">I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.</p>	

RUBBED DOWN BY	PRINT NAME
----------------	------------

<b>TITLE</b> <b>STANDARD POSITIONS</b>	
<small>DRAWN BY</small> C.LARKIN	<small>DATE</small> 28/03/2024
<small>CUSTOMER</small> CUSTOMER	

NOTE:  
 All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

DESCRIPTION:

**PW680.AG**

ALL DIMENSIONS IN MM - DO NOT SCALE

NOTES		TANK SPECIFICATION :	
<small>DATE</small>	04/02/2023	<small>INTERNAL DIMENSIONS</small>	1220 x 915 x 610mm
<small>FIRST ISSUE</small>	xxx	<small>EXTERNAL DIMENSIONS</small>	1380 x 1075 x 650mm
<small>VERSION</small>	xxx	<small>NOMINAL CAPACITY</small>	680 Litres
		<small>INSULATION THICKNESS</small>	25mm
		<small>STEEL BRACINGS</small>	NONE
		<small>ENCAPSULATED BASEBOARD</small>	NONE
		<small>TANK COLOUR</small>	GREY 00A05



SCALE:1:20

SHEET 1 OF 1

