


View 4

View 3

View 2



View 3

- Connections:
- A - Inlet 1 No pad T1 only
 - B - Lid vent
 - D - Overflow 1 No pad T2 only
 - E - Warning pipe 1 No pad T2 only
 - F1 - Outlet 1 No pad T1 only
 - G - Drain 1 No T1 pad only

Drawing Approval Date	
Name	
Signature	
<p style="font-size: small; color: red;">I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.</p>	

RUBBED DOWN BY	PRINT NAME
TITLE	STANDARD POSITIONS
DRAWN BY	D.PRYJMACHUK
DATE	28/03/2024
CUSTOMER	CUSTOMER

NOTE:
All Tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:
PW1135.AG

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	1524 X 915 X 812MM
EXTERNAL DIMENSIONS	1680 X 1080 X 905MM
NOMINAL CAPACITY	1135 Litres
INSULATION THICKNESS	25mm
STEEL BRACINGS	1 No 25MM
ENCAPSULATED BASEBOARD	NONE
TANK COLOUR	GREY 00a05

