



Connections:

A - Inlet	1 No pad T1 only.
B - Lid vent	None
D - Overflow	1 No pad T2 only
E - Warning pipe	1 No pad T2 only
F1 - Outlet	1 No pad T1 only.
G - Drain	1 No pad T1 only.

Drawing Approval Date	
Name	
Signature	

I am signing to approve this drawing to progress my order in the build program. I accept that I cannot cancel this order following my signature of approval.

RUBBED DOWN BY	PRINT NAME
TITLE	STANDARD POSITIONS
DRAWN BY	D.PRYJMACHUK
DATE	15/04/2024
CUSTOMER	CUSTOMER

NOTE:
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:
PW3001.INS

ALL DIMENSIONS +/- 5mm UNLESS OTHERWISE STATED

NOTES	DATE	14/02/2023
FIRST ISSUE	xxx	
VERSION	xxx	

TANK SPECIFICATION :

INTERNAL DIMENSIONS	2000 x 1000 x 1500mm
EXTERNAL DIMENSIONS	2202 x 1202 x 1600mm
NOMINAL CAPACITY	3000 Litres
INSULATION THICKNESS	25mm
STEEL BRACINGS	3 No 40MM BANDS
ENCAPSULATED BASEBOARD	NONE
TANK COLOUR	GREY - 00A05

