



TITLE  
PW501.DIV.AG - TD

DRAWN BY  
D.PRYJMACHUK

DATE  
09/10/2024

**NOTE:**  
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:  
PW501.DIV.AG - TD

PW501 One piece cold water storage tank AG  
Air Gap

SCALE:1:20      SHEET 1 OF 1

TANK SPECIFICATION :	
INTERNAL DIMENSIONS	1000mm x 500mm x 1000mm
EXTERNAL DIMENSIONS	1160mm x 660mm x 1009mm
NOM. CAPACITY	500 Litres
DRY WEIGHT	xxx KG
INSULATION THICKNESS	25mm
MATERIAL	GRP

