



Internal Central Division

TITLE  
PW570.DIV.AG - TD

DRAWN BY  
D.PRYJMACHUK

DATE  
09/10/2024

**NOTE:**  
All tanks must be fully supported on a flat level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:  
PW570.DIV.AG - TD  
PW570 One piece cold water storage tank AG Air Gap

SCALE:1:20 SHEET 1 OF 1

**TANK SPECIFICATION :**

|                      |                        |
|----------------------|------------------------|
| INTERNAL DIMENSIONS  | 990mm x 760mm x 760mm  |
| EXTERNAL DIMENSIONS  | 1150mm x 925mm x 799mm |
| NOM. CAPACITY        | 570 Litres             |
| DRY WEIGHT           | xxx KG                 |
| INSULATION THICKNESS | 25mm                   |
| MATERIAL             | GRP                    |

