



TWO PIECE
SPLIT TANK



TITLE
PW500-2.DIV.AG - TD

DRAWN BY
D.PRYJMACHUK

DATE
16/10/2024

NOTE:
All tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. It is essential that the user refers to the conditions of installation document prior to the installation of the tank. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and fitted correctly when water is contained within the tank.

DESCRIPTION:
PW500-2.DIV.AG - TD
PW500 Two piece cold water storage tank AG
Air Gap

SCALE:1:20 SHEET 1 OF 1

TANK SPECIFICATION :

INTERNAL DIMENSIONS	1000mm x 1000mm x 500mm
EXTERNAL DIMENSIONS	1180mm x 1180mm x 539mm
NOM. CAPACITY	500 Litres
DRY WEIGHT	xxx KG
INSULATION THICKNESS	25mm
MATERIAL	GRP

